



United Nations Development Programme

ITB/093/17 – Provision of Electrical Materials to Bashir Electrical Network-Part 1

Questions and Answers

Question 1

Please note that the attached “Technical Compliance Sheet” does not contain the details for items 8, 9, 10, 11, 12 and 13 (*of the BOQ – addition by UNDP*), please advise us that how we can collect the technical details for these items.

Answer to Question 1:

Below table summarizes the additional details for the referenced BOQ items:

No.	BOQ Items	Technical Details
8	Supply Cable suspended size (3x95+50+16) mm2 best quality	Suspended twisted cable 3x95+50+16 mm2 (3x95+50 wires RST twisted cable for low voltage & line 16 for lighting)
9	Supply suspended Clamp best quality	The laminate must be aluminum coated with plastic with good insulation & not less length from 30 cm
10	Supply Tension Clamp best quality	It should be packed with a temperature of 60 ° C with a tight seal
11	Supply Hook pole best quality according	It must be well-insulated with a tight seal made of good steel that bears the air conditions
12	Supply Bkls with Steel Band best quality	A good electrical insulator with a wire of at least 70 mm 2, with a strong conductive coupling bearing more than 60 ° C
13	Supply Connector best quality	It is made of good copper and bears all the conditions and it is not less than 45 cm with the link