

28 May 2017

Subject: RESPONSE TO REQUEST FOR CLARIFICATION Part 3 - IRQ ITB-154/17, Supply of Materials for 132kV Transmission Line Between Tal-Awailnat and Sinuni Sub-Districts (45 km length)

To: All Bidders,

Questions	Response
in the BOQ item (7) you are referring to a rear stand damaged conductor and in annex (G) you are referring to a (Reeler) this is garbled information please be specific on what you are looking for.	The End User requirement is for a Reeler
the size of the ACSR conductor <i>must be known</i> in order to supply the correct suspension kit. there are various sizes in ACSR conductor sizes in 132Kv and therefore different size tension/ suspension kits.	<p>The ACSR conductor size is not mentioned but the code name is mentioned, i.e. first item of the BoQ it is mentioned "Teal" conductor.</p> <p>Please also refer to Ministry of Electricity Standard Specifications page 40 & 47; the specifications of Teal and Dorking is provided.</p>

Please be guided accordingly.

Thank you



Ijaz Hussain
Head of Procurement, Service Center