

AMENDMENT 1

RFQ-YEM-0027-2017 – Supply and Install Caravan/Prefab

**This Amendment issued to reply to the
Vendors clarification request as per the
below table:**

Kindly find the clarification to some of the comments concerning the Caravan - RFQ-YEM-0027-2017:

| NO | Comments | Answers |
|----|---|---|
| 1 | The distance between the Caravan and the nearest manhole to the external sewage, purposed to recognize for installing the sewage piping line? | In regarding the distance between the Caravan and the nearest manhole ,it will be maximum 20 m |
| 2 | The dimensions of the based foundations which shall be installed for caravan supported? | In regarding on this concerning we would like to inform you that we have been site visit and explained all things , however ,the dimensions of the based foundations are 60*60 cm and depends on the level between pedestrian Footpath and street level |

| | | |
|---|---|---|
| 3 | The Electrical system, shall be installed for the Caravan from outside and is there any nearest electrical supply node? | In regarding the electrical system , lamps and sockets will be according to the standards and extend to the nearest electrical point , the distance will be maximum 50 m |
| 4 | How many needed windows in the Caravan. | We would like to inform you that the windows in the Caravan are two, one for the caravan 100*100 cm and the second for the kitchen 40*40 cm. beside there are three doors for the caravan . |