## **United Nations Development Programme** *Iraq*



2 June 2017

Subject: RESPONSE TO REQUEST FOR CLARIFICATION Part 4 - IRQ ITB-154/17, Supply of Materials for 132kV Transmission Line Between Tal-Awailnat and Sinuni Sub-Districts (45 km length)

All Bidders are advised of the following response to requests for clarifications:

| QUESTIONS   | RESPONSE   |
|---|--|
| paragraph below written in the table meters not specified specific  | Annex G point 4 hereby corrected to read as 175 cm.  |
| Annex G point 4   |  |
| Maximum drum diameter is 175 meter .  | g =  |
| ACSR means Aluminum conductor steel reinforced, teal has no relevance to size.  | The ACSR conductor size is not mentioned but the code name is mentioned, i.e. first item of the BoQ it is mentioned "Teal" conductor.                |
| the ACSR comes in 5 different cross-sectional areas, all of them are ACSR. if you don't state the cross-section then you will likely receive the wrong size for tension and suspension set that can not carry the ACSR.                           | Please also refer to Ministry of Electricity Standard Specifications page 40 & 47 (Attachment1); the specifications of Teal and Dorking is provided. |
| so do avoid errors kindly go back to the end user and obtain the cross section of the ACSR. in order to supply the correct suspension and tension set which you are asking for. the MOE specs does not say what is the cross section of the ACSR. |  |
| The specifications of annex (G) has no relevance to a reeler. Can you send us a picture of what a reeler is?  |  |
| Could you please give us more technical specifications and drawing of item 7-Rear stand for damaged condactor   | It should fulfill the requirements that is mentioned in Annex G  |

## **United Nations Development Programme** *Iraq*



Kindly clarify the name of delivery location for the above mentioned ITB since we are not familiar in the (TAL- Awailnat and Sinuni Sub-Districts (45 Km Length)). Delivery location is in Erbil at the warehouse of the Contractor who was contracted to install the transmission lines (Iraq-Erbil-100m/Peshawa Qazi Str.- No. 124)

Please be guided accordingly.

Thank you.

Ijaz Hussain

Head of Procurement, Service Center