



July 5, 2017

Subject: **Notice to Bidder & Response to Bidder's Request for Clarification**
Ref: **IRQ-ITP-250/2017**

**Turnkey Project for the Provision of Supply, Erection, Testing, Commissioning, Engineering, Design,
Training Of Personnel for Seven Electrical Substations in Mosul**

A. Extension of deadline

To allow more time for companies to prepare the required documentations, the deadline for the submission of interest to pre-qualify has been extended from 17 July 2017 to 25 July 2017. Deadline for submitting request for clarifications/questions is therefore also been extended to 17 July 2017.

B. Response to Bidder's Request for Clarification

No#	Bidders Requests for Clarification	UNDP Response to Bidder's "Request for Clarification"
1	There is no information about the scope of works or technical specifications. Annex 7 is empty. Please, let me know the size of the substations, if there is a price of reference, and any other information in order to evaluate our participation in the tender	At this stage of the process, interested companies are only required to submit all the relevant documents required as listed in the ITP. The detailed solicitation documents, full Scope of Works, Terms of Reference, Specifications and Payment Term/(s) will be provided only to those who will pass this Invitation to Prequalification (ITP). Annex 7- Brief Scope of Work attached.
2	We would like to inquire about this: 1-Technical Specification of the (Seven Electrical Substations) 2- Transformation ratio & substations capacity...etc	Brief Scope of work with brief specifications of the substations are provided in Annex-7.
3	kindly ask you to send us copy of Annex 7 "Brief Scope of Works/Specifications"	Attached
4	Can you submit to our side the full specification for requested Sub Station which we interested in to start our work on , as we didn't find in the advertised documents	Brief Scope of work with brief specifications of the substations are provided in Annex-7.
5	You are kindly requested to provide technical specifications of those substations (it is not clear whether they are 132-33 MVA or 33-11) besides other required specifications, in addition the terms of contract are not available such as time of completion and terms of payments, maintenance period----etc	Brief Scope of work with brief specifications of the substations are provided in Annex-7.
6	It would be grateful if you provide us some details about the size and grant of this Project	Brief Scope of work with brief specifications of the substations are provided in Annex-7.

8	<p>Please clarify as follows:</p> <p>1. Which is the voltage level of the substations required by this Pre – qualification? Please define the maximum size of the file that can be sent by e-mail - whether it is five or seven megabytes</p>	<p>The voltage level has briefly been mentioned in the attached scope of work with details on the mobile substations.</p> <p>The file size per email is 7 MB</p>
10	<p>please inform us about the following:</p> <p>1-What is the type of these substations, are they Fixed or Mobile Substations?</p> <p>2-What is the capacity of these substations? 16 MVA, 25 MVA or 32 MVA?</p> <p>3-what is the Rated voltage of these substations, 132/11 KV or 132/33 or 33/11 KV?</p> <p>4-are these substations identical with the same size and Rated voltages?</p>	<p>These are mobile sub-stations. Brief specifications are attached.</p> <p>These are 33/11.5 kV 2*31.5 MVA</p> <p>Yes</p>
11	<p>We are asking your kind office to provide us further information on the following clarifications ;</p> <ol style="list-style-type: none"> 1. In Annex-7, Brief Scope of works/specification, is the page empty? 2. The specific Location coordinates (Latitude and Longitude) of Substations. Is the seven (7) Substations are inside Mosul City Center ? or around Mosul Governorate? 3. How about the Payment Terms and conditions? 	<p>All the information is provided in the attached scope of work.</p>
12	<p>The below are not the clarified information in the tender for detailed designing & budgeted tender, so kindly requesting the possible information that you could provide.</p> <p>QUESTIONNAIRE FOR SUBSTATION AT MOSUL</p>	<p>Please note that the intended request is not to provide the financial at this stage. The detailed solicitation document will be shared with the potential bidder who will considered technically qualified and have relevant experience and expertise and have sound financial standing. Please see the brief scope of work attached at Annex-7</p>
13	<p>1) Can we understand how much is the overall project worth? Just like an approximate range in order to understand the entity of the overall project and see if we can bid for it</p> <p>2) Can we know the percentages of the bid bond and the performance bond?</p> <p>3) At last, for the references requested, can they be from the country where the company is legally registered or they need to be international?</p>	<p>1) Please see the brief scope of work in order to get the fair idea about the budget. It is not UNDP policy to share the budget.</p> <p>2) At this stage, it is not required.</p> <p>3) It is international tender.</p>
14	<p>Are those employees need to stay at work site or they can back forth daily? Also Do we need to provide transportation and live support for them?</p>	
15	<p>We need to understand further information on the scope and specifically on the locations of the substations!</p>	<p>The Location is Mosul City in Iraq</p>
16	<p>For clarification purposes of IRQ-ITP-250/2017;</p> <p>1 -In instruction to applicants it says that;</p> <ul style="list-style-type: none"> o <input checked="" type="checkbox"/> Dunn & Bradstreet rating – Provide Dunn and Bradstreet Report, for more information/registration, bidders are requested to visit www.dnbsame.com. If not available, those 	<p>Companies/Firms are required to Submit Dunn & Bradstreet at this stage in order to ensure that the companies are financially sound. The address is given in order to provide facilitation to the potential firms/companies/manufacturer to coordinate further.</p>



	<p>prequalified will be requested to provide such report at the Invitation to Bid stage.</p> <p>-In Evaluation Criteria for the Pre-Qualification Process it says that;</p> <ul style="list-style-type: none"> o D & B Report must be submitted. <p>Since this report takes time to be prepared we would like to provide Dun & Bradstreet Report at the Invitation to Bid stage. Can you please clarify this point?</p> <p>2- IRQ-ITP-250/2017 tender consists of Seven Electrical Substations in Mosul. Can you please clarify the Voltage Capacities of the substations and clarify whether the construction job is a renovation of the previous substations or completely new work from the beginning stage.</p>	<p>It is required. However, in case it is not ready you can submit the proof that you have requested for it. UNDP at the time of finalization of process will obtain the report.</p> <p>Mentioned in the Section-7 brief scope of work.</p>
17	<p>I would like to know the bidding deadline date and process</p>	<p>Completed applications as per the requirements stated in the Data Sheet (DS) should be submitted electronically via email before or on 17 July 2017, 1400 hours (Baghdad Time) to bids.iraq.sc@undp.org.</p>

Please be guided accordingly.

Yours sincerely

Mohammed Siddig A Mudawi
Head of Operations Service Center
Deputy Country Director Operations; a.i.
UNDP, Iraq