



Trench width $W = 6D$
Single core cable diameter $= d$
 $D = 2d = 110\text{mm}$ (approximately)
 $W = 6 \times 110 = 660\text{mm}$
The Trench should be not less than 660mm and not more than 800mm

UNDER GROUND CABLE :
2 Underground Feeder 33kv Trefoil

DRAWN BY : Ayoub Hussein

SHEET TITLE : Power Cable Trench

Scale: NTS

Date:

Sheet No. Dra. C