

Q&A Distribution equipment and materials

ITB-309/17

Renovation of Talkaif WTP, Ninawa Governorate

	Question submitted bidders	Answer by Technical team and procurement
1	For MV 11kV switchgear your requirement is (Same as existing (Schneider)) and model MCset , when we checked the photo we found the panels is ASEA (ABB) and retrofit later by Schnider. While your request is new switchgear then (we request) add ABB as required brand due the installed base was ABB, or add ABB with other brand.	Schneider was recommended due to the existing condition and standardization. However, ABB is also acceptable but with no additional cost that might arise during Installation