

## **Amendment No.1**

<b><u>To:</u></b>	<b>Bidders</b>
<b><u>From:</u></b>	<b>UNDP Syria</b>
<b><u>Subject:</u></b>	<b>Provision of Maintenance for Waste water network in Al Kallaseh Neighborhood in Aleppo o Support Field Monitoring and Evaluation</b>
<b><u>Reference:</u></b>	<b>UNDP-SYR-ITB-114-17</b>
<b><u>Date:</u></b>	<b>17-09-2017</b>

### **Deadline of Submission of Quotation in article No. 21 page 21:**

The deadline for proposal's submission has been Changed to be as follows:

21	C.21.1 D.24	Deadline for the Submission of Quotation	<b><i>Sunday, September 24, 2017 at or before 2:00PM Damascus time</i></b>
----	----------------	--	--

### **Answers to bidders' requests for clarifications:**

UNDP Syria Procurement Unit has received questions regarding the subject Tendering Procedure. All questions received to-date are documented below with respective answers:

<b>No.</b>	<b>Questions &amp; Answers</b>
1	<p>The plans that the contractors must have to prepare our offer, which shows the length and height of the line, please if you can advise how to get them.</p> <p><a href="#">The sewers layout drawing including the lengths and levels, is on the last page of the attached technical conditions in Annex. 1.</a></p>
2	<p>Is the contractor required to asphalt the roads?</p> <p><a href="#">The contractor is not responsible for cutting the existing asphalt layer nor applying a new asphalt layer after completion of his works.</a></p>

3	<p>In case of electronic submission, how should I send the bid security check?</p> <p>You have the option to send your bid as a soft copy by email, or as a hard copy by hand, but the bid security should be submitted as a hard copy by hand only before the deadline.</p>
4	<p>We need the technical information about the requested HDPE pipes and the Nivo, also the drawings and the diagrams for this project (dwg format).</p> <p>All available technical information is attached in this amendment files under the: Annex. 1 &amp; 2</p>