



Invitation To Bid (ITB)

Subject:	DATE: November 7, 2017
Establishment of a Long-Term Agreement (LTA) for the supply, delivery, commissioning of, and training for warehouse materials handling equipment.	REFERENCE: ITB UNDP HIST 31-2017

CLARIFICATIONS TO BIDDERS. Nr. 1

Important: All bidders are kindly requested to take note of the following clarifications in response to enquiries.

Q1; *In section 3, paragraph A (page 27) under "In summary the supplier will be responsible for" it is mentioned "Satisfying themselves and UNDP that the completed floor condition is suitable for the operation of their trucks". Please advise what is the meaning of that? How can we advise on a Floor which we never saw and we did not build?*

A1; This asked the successful vendor to comment on the floor condition when completed ie when built. Due the lift height of the narrow aisle lateral stackers the flatness of the floor is an important criteria. The floor specifications are given in the building document and are correct for the machines being specified. If the tender wishes to state the floor specification that his machine requires then he must add this to his tender return. Sometimes after several months of machine operation a supplier complains that the floor is causing high maintenance cost. This paragraph has been added to avoid that situation.

Yours sincerely,

Alfonso Buxens, Procurement Advisor, GF Partnership PSM Team