

**RFQ-440/17 Supply, installation and commissioning of IT equipment and software for  
Qayara power plant**

**Site visit: 20 November 17**

**QUESTIONS AND ANSWERS**

<b>QUESTIONS RAISED BY BIDDERS DURING SITE VISIT</b>	<b>RESPONSES PROVIDED BY UNDP ENGINEER</b>
is there any installed software on any computer in the station now?	<b>there are different software and computers used at the plant but no connection to our request (water treatment plant computers)</b>
explain the type and version of installed PLCs which will be connected to the wanted computers	<b>RS Logix 5000</b>
if there is any copy or data for the old logo please send to us so that we to take in our considerations	<b>the available backup can be given the selected contractor</b>