

Site Visit Report



ITB-420/17 - Rehabilitation of Police HQ and Al Yarmuk 2, Police Station		Date of Site Visit	Nov. 15, 2017	Escorted by?		Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
Time of Site Visit		Name(s) and job title of Gov. Rep.				
Start	End					
10:00 Am						
Names of companies attended		Rep. name		Mobile/Email		Signature
Al Wess		Firas Mahmud		07504139256		Referred to attached list
						Referred to attached list
						Referred to attached list

QUESTIONS AND ANSWERS

Item No:	BIDDER QUESTIONS ASKED	UNDP RESPONSES GIVEN
1	Contractor ask about the fence	Refer to the exact old location of the site fom all directions
2	Should the contractor remove all the rubbles debris from the site, and where to transport it	Yes, you should remove all the debris, rubbles from site to an approved location by the authorized by the government authority.
3	Is the package for the two site location? Head quarter and Tarmuk the second PS	Yes
4	Which building should be removed from the head quarter compound	The leader building should be removed, because it is heavily damaged.
5	The new roofing of the car steeling monitoring building, should it be in concrete?	Yes, its reinforced concrete to be interacted with the old slab.

UNDP

FFIS

DATE: 15/11/2017

Bidders Information (

)

focal person

name: ALi Habib

tel. 07713902962

ITB 420/17.


Coordinates

LATITUDE

LONGITUDE

36.334924

43.145531 43.140206

#	Name of Company	authorized person	Email	Telephone	Signature
1	ALwess	Firas mahmoud	drkid5@gmail.com	0759 9139256	
2					
3					
4					
5					
6					
7					
8					
9					

UNDP

FFIS

DATE:

Bidders Information (

)

focal person

name:

tel:

Coordinates

LATITUDE

LONGITUDE

#	Name of Company	authorized person	Email	Telephone	Signature
10					
11					
12					
13					
14					
15					
16					
17					



Signature:

Name: Ali Habib

Position: Civil Engineer

Date: Nov. 15, 2017