



03 January 2018

**Subject: Rehabilitation of West Mousl Partially Defected Substation, Ninawa Governorate**  
**"Note to Bidders"**

Dear Bidders,

This is to clarify that the "Battery Charger" for Item No. 5 "110V Battery, Battery Charger and 110VDC Distribution board" of Technical Compliance Sheet shall be read as following, as stated in the BOQ:

"Station DC System, the charger should be 230V, 1 phase, 2-wire, 50 Hz supply with supply voltage variation of plus and minus 10%"

All other clauses and conditions shall remain unchanged.

Please be guided accordingly.

Thank you

A handwritten signature in blue ink, appearing to read 'A. Qarman', is positioned above the printed name of the signatory.

Anas Fayyad Qarman  
Operations Manager  
UNDP