



United Nations Development Programme

ITB-501/17 – Supply and Installation of 25MVA Mobile Substation for Ifraz Water Treatment Plant - Erbil Governorate, Iraq

Questions and Answers – 3

Date: 30 Jan 2018

No	Question	Answer
1	<p>In the (02__Section_7__PriceScheduleForm_BOQ), item A (Provision of 11kV Switchgear for Mobile Substation 25 MVA and 11kV equipment with all required connection and accessories)</p> <p>Item 5, MV Cables, Termination, Cable Trays (Includes outgoing Feeders)</p> <p>Kindly confirm if the outgoing feeder is to be included in the Contractor's Scope or not?</p>	<p>Outgoing feeders are not part of the required services to be done by the contractor as It's not within the scope of work of UNDP's tender.</p> <p>However, there are four existed standing Outgoing Feeders that will be required to be connected to the new 25MVA Mobile Substation.</p>