United Nations Development Programme



28 February 2018

Subject: Response to Bidders Request for Clarification: ITB-072/18 – Rehabilitation of 3 Substations

Bidders are advised of the following response to request for clarifications:

The existing Circuit breaker short circuit is 31.5kA/1sec.
 Equivalent offer can be accepted if and only if: The offered equipment complies with Iraqi technical specifications and related IEC Standards. Bidders cover the cost for all Mechanical and electrical adaptation, Technical and schematic drawings modifications. Confirmation and warranty that the equivalent offer will match completely with the existing system without any future problems.

	documents to show that similar adaptation been carried out successfully.
Second round of site visit	Due to the requests of some bidders, a second round of site visit is scheduled on Sunday, 4 March 2018, from 10:00 hours – 14:00 hours.
	Contact person for the site visit is: Eng. Himadad Tahir Bahri Email: himdad1980@yahoo.com; Tel: 00964 (0) 750 464 7315
Extension of deadline of submission	To give enough time for bidders to prepare their bid after the site visit, the deadline of submission of bids has been extended from 6 March 2018 till 8 March 2018.

Please be guided accordingly.

ljaz Hussain

Head of Procurement, Service Center