

Reference: UNDP-CYP-ITB-013/2018

Subject ITB: Support to cultural heritage monuments of great importance for Cyprus, Phase V  
Conservation Works

Lot 1: Panagia Church Lot 2: Agios Artemon Church

Clarifications no:2 dated 13 March 2018

No	Questions	Answers
	<b>lot 1: Panagia Church</b>	
1.	Tender Bank Guarantee is not allowed in BOQ? Where are we going to allow for this item?	Please refer to Clause 12 of the Section 2: Instruction to Bidders.  <i>`Clause 12 – Cost The Bidder shall bear any and all costs related to the preparation and/or submission of the Bid, regardless of whether its Bid was selected or not. UNDP shall in no case be responsible or liable for those costs, regardless of the conduct or outcome of the procurement process. `</i>
2.	Most of the materials are not available in Cyprus; we will use equivalent that are locally available.	Although this is a statement, the contract conditions allow for the provision of equivalent materials if approved by the Engineer.  Please indicate the materials that are not available in the market.
3.	BOQ Items L.12.24, L.12.25, L.12.26 (internal plaster) is it gypsum or lime based?	Hydraulic lime will be used.
4.	There is not any scaffolding allowance in BOQ (internally or externally), where are we going to allow for this?	Please see section 7.0 dated 13 March 2018 (supplementary to section 7) applicable to 7.1 and 7.2 BoQs.
	<b>lot 2: Agios Artemon</b>	
5.	We have experienced in Martinengo walkways that the given fencing detail (S.D.02 - Gazikoy which is same with Martinengo) is not applicable and changed the details. We suggest to change the details for this bid as well and price it accordingly.	Suggestion is noted but no changes can be made to the designs at this stage.