

Dated: 30 April 2018

Addendum-03

IRQ10-ITB-229-18 Rehabilitation of General Authority of Underground Water-Ninawa Branch, East Mosul


Clarification of Line Item of BOQ

Please be advised of the following questions asked by the bidder and UNDP clarifications:

Item No.	Bidders Question	UNDP Response
Item No. 2 & 16 of Civil Works	Referring to items 2 and 16 the depth of the excavation was not mentioned Please let us know the depth	Winning contractor should prepare shop drawing (prior of proceeding with excavation works) as per the existing condition and accordingly excavate to reach the right formation level / stiff layer to place the foundation.
Item No. 42 & 43 of Civil Works	Concerning the two items 42 and 43 the Roof Drain Gutter Is it double or two different items	The roof gutter in items 42 and 43 are two different items.

This addendum -03 forms an integral part of the ITB 229-18. All other Terms and Conditions in this ITB will remain unchanged.

Yours Sincerely



Ijaz Hussain

Head of Procurement/Procurement Specialist
UNDP Service Center