



May 08, 2018

ADDENDUM 01

ITB 299/18 - Installation of Steel Reservoir with 5 Wells in Karamles-Al Hamdaniah District-Ninawa Governorate

Site Visit

Following clarifications were sought. Please see the responses

Item No.	Bidders Questions	UNDP Response
1.	Why are there two types of generators?	One is 250KVA for the steel reservoir and the other is 40kva for the wells.
BOQ under civil works line - 21, 23,24	Should the pipe be polyethylene or another type?	Yes, it must be polyethylene.

This Addendum -01 forms an integral part of the ITB - 299/18. All other Terms and Conditions in this ITB will remain unchanged.

A handwritten signature in blue ink, which appears to read 'Piero Franceschetti', is positioned above the typed name and title.

Yours sincerely,

Piero Emanuele Franceschetti
Head of Service Center, UNDP, Iraq