



QUESTIONS AND ANSWERS
REPORT No.1

To:	Bidders
From:	UNDP Syria
Subject:	Rehabilitation of the third and fourth floors of Al Assad Hospital in Deir Ezzour City
Reference:	UNDP-SYR-ITB-040-18
Date:	12-05-2018

Answers to bidders' requests for clarifications:

UNDP Syria Procurement Unit has received questions regarding the subject Tendering Procedure. All questions received to-date are documented below with respective answers:

Questions & Answers
تحديد قيمة امبير القاطع الثلاثي وتحديد طراز القاطع /MCB-MCCB-IS/ : القاطع الثلاثي 63 امبير وهو مذكور بدفتر الشروط الفنية من افضل الأنواع الاوربية أو ما يعادل .
تحديد عدد لمبات في جهاز اناارة نيون 18 واط . لا يوجد عدد لمبات في جهاز النيون ، الانارة عبارة عن جهاز يعمل بتقنية LED 220 فولت وذكر بالخطأ جهاز اناارة نيون وتم الإجابة على هذا السؤال ضمن الزيارة الميدانية.
تحديد مقطع الكابل في النقطة الضوئية (3*1.5مم او 3*2.5مم 2) مقاطع الاسلاك كما هو مذكور في دفتر الشروط 4 – 2 – 1.5 مم مربع وذلك حسب استخدام النقطة اذا كانت لانارة او لمأخذ صناعي ...الخ.
تحديد عرض ابواب المصاعد مع ذكر شرح فني بسيط عن الوضع الراهن . بالنسبة للابواب المصاعد تم الكشف عليها بالزيارة الميدانية وهي بحاجة لتبديل كما ذكر بدفتر الشروط الفنية، وذكر صيانة المصاعد مع استبدال الأبواب بالطابقين الثالث والرابع وليس صيانة الأبواب.
تحديد قيمة امبير المأخذ الصناعي بالنسبة للمأخذ الكهربائي كما هو مذكور في دفتر الشروط 16 امبير مزود بقطب تأريض نوع جيد وتكون كتيمة ومأخذ الحاسب يكون نوع شوكو 16 امبير وجميع التفاصيل مذكورة في دفتر الشروط الفنية.