

Amendment № 01

TO REQUEST FOR QUOTATION

Date: May 11, 2018
Regarding: RFQ/021/18 – Supply of power transformers to Karakalpakstan

This Amendment is submitted to RFQ/021/18 announced on May 2, 2018, for the "Supply of electrical power transformers to Karakalpakstan"

Changes are as follows:

1. Annex 1 "Technical requirements and specifications" – is revised and to be read as stipulated in Annex 1 "Technical requirements and specifications" to this Amendment № 02.
2. Annex 2 "Bid Submission Form», "Form for Submitting Supplier's Quotation" – is revised and to be read as stipulated in Annex 2 "Bid Submission Form», Part 1 "Form for Submitting Supplier's Quotation" to this Amendment № 01.
3. All relevant texts of the RFQ concerning the deadline for submission of quotations should be read in the following edition:

"May 21, 2018, Tashkent time 18:00 (GMT +5)"

All Amendments to the RFQ/021/18 are an integral part of it, and all participants must comply with the requirements stipulated by such additions. Any deviation from the claims made by amendments to this RFQ may result in consideration of the proposal as not meeting the requirements and withdrawing from further evaluation.

All other terms and conditions of the RFQ/021/18 remain unchanged.

Technical requirements and specifications

№	Description and specification of goods	UOM	Q-ty	Delivery address	
1	<p>Complete set of transformer substation of rural type: Complete power transformer substation for outdoor installation; it serves for receiving three-phase current electric power with a frequency of 50 Hz, a voltage of 6 or 10 kV and transforming it into electricity with a voltage of 0.4 kV and supplying it to separate populated locations and industrial facilities.</p>	set	5	Muynak district – 3 sets; Takhtakupir district – 1 set; Shumanay district – 1 set	
	Type of transformer				Oil, 3 phased
	Power of transformer				160 kVA
	Rated voltage at the HV (High Voltage) side				6; 10 kV
	Rated voltage at the LV (Low voltage) side				0,4 kV
	Current Frequency				50Hz
	Outside temperature				-40 + 45 C°
	Impedance voltage				4,5-5,5%
	<p>Types of security: -from phase-to-phase short circuits; -from atmospheric overvoltage; -from overload and short circuits of 0.4 kV lines; -from short circuits of heating circuits, lighting circuits; - gas protection of the transformer;</p>				
	<p>The set additionally includes:</p>				
	1.1. Disconnecter Linear External Double-layer - 1pc.				
1.2. Automated Energy Accounting System (counter, modem) - 1pc.					
2	<p>Complete set of transformer substation of rural type: Complete power transformer substation for outdoor installation; it serves for receiving three-phase current electric power with a frequency of 50 Hz, a voltage of 6 or 10 kV and transforming it into electricity with a voltage of 0.4 kV and supplying it to separate populated locations and industrial facilities.</p>	set	1	Takhtakupir district	
	Type of transformer				Oil, 3 phased
	Power of transformer				250 kVA
	Rated voltage at the HV (High Voltage) side				6; 10 kV
	Rated voltage at the LV (Low voltage) side				0,4 kV
	Current Frequency				50 Hz
	Outside temperature				-40 + 45 C°
	Impedance voltage				4,5-5,5 %
	<p>Types of security: -from phase-to-phase short circuits; -from atmospheric overvoltage; -from overload and short circuits of 0.4 kV lines; -from short circuits of heating circuits, lighting circuits; - gas protection of the transformer;</p>				
	<p>The set additionally includes:</p>				
	1.1. Disconnecter Linear External Double-layer - 1pc.				
1.2. Automated Energy Accounting System (counter, modem) - 1pc.					
3	<p>Complete set of transformer substation of rural type: Complete power transformer substation for outdoor installation; it serves for receiving three-phase current electric power with a</p>	set	1	Shumanay district	

frequency of 50 Hz, a voltage of 6 or 10 kV and transforming it into electricity with a voltage of 0.4 kV and supplying it to separate populated locations and industrial facilities.				
Type of transformer	Oil, 3 phased			
Power of transformer	100 kVA			
Rated voltage at the HV (High Voltage) side	6; 10 kV			
Rated voltage at the LV (Low voltage) side	0,4 kV			
Current Frequency	50 Hz			
Outside temperature	-40 + 45 C°			
Impedance voltage	4,5-5,5 %			
Types of security:				
-from phase-to-phase short circuits;				
-from atmospheric overvoltage;				
-from overload and short circuits of 0.4 kV lines;				
-from short circuits of heating circuits, lighting circuits;				
- gas protection of the transformer;				
The set additionally includes:				
1.1. Disconnecter Linear External Double-layer - 1pc.				
1.2. Automated Energy Accounting System (counter, modem) - 1pc.				

Part 1: FORM FOR SUBMITTING SUPPLIER'S QUOTATION
(This Form must be submitted only using the Supplier's Official Letterhead/Stationery)

We, the undersigned, hereby accept in full the UNDP General Terms and Conditions, and hereby offer to supply the items listed below in conformity with the specification and requirements of UNDP as per RFQ Reference No. RFQ/021/18.

TABLE 1: Offer to Supply Goods Compliant with Technical Specifications and Requirements

No	Description and specification of goods	UOM	Q-ty	Delivery address	Unit price (currency) ¹	Total price (currency)														
1	<p>Complete set of transformer substation of rural type: Complete power transformer substation for outdoor installation; it serves for receiving three-phase current electric power with a frequency of 50 Hz, a voltage of 6 or 10 kV and transforming it into electricity with a voltage of 0.4 kV and supplying it to separate populated locations and industrial facilities.</p> <table border="1"> <tr> <td>Type of transformer</td> <td>Oil, 3 phased</td> </tr> <tr> <td>Power of transformer</td> <td>160 kVA</td> </tr> <tr> <td>Rated voltage at the HV (High Voltage) side</td> <td>6; 10 kV</td> </tr> <tr> <td>Rated voltage at the LV (Low voltage) side</td> <td>0,4 kV</td> </tr> <tr> <td>Current Frequency</td> <td>50Hz</td> </tr> <tr> <td>Outside temperature</td> <td>-40 + 45 C°</td> </tr> <tr> <td>Impedance voltage</td> <td>4,5-5,5%</td> </tr> </table> <p>Types of security: -from phase-to-phase short circuits; -from atmospheric overvoltage; -from overload and short circuits of 0.4 kV lines; -from short circuits of heating circuits, lighting circuits; - gas protection of the transformer;</p> <p>The set additionally includes: 1.1. Disconnecter Linear External Double-layer - 1pc. 1.2. Automated Energy Accounting System (counter, modem) - 1pc.</p>	Type of transformer	Oil, 3 phased	Power of transformer	160 kVA	Rated voltage at the HV (High Voltage) side	6; 10 kV	Rated voltage at the LV (Low voltage) side	0,4 kV	Current Frequency	50Hz	Outside temperature	-40 + 45 C°	Impedance voltage	4,5-5,5%	set	5	Muynak district – 3 sets; Takhtakupir district – 1 set; Shumanay district – 1 set		
Type of transformer	Oil, 3 phased																			
Power of transformer	160 kVA																			
Rated voltage at the HV (High Voltage) side	6; 10 kV																			
Rated voltage at the LV (Low voltage) side	0,4 kV																			
Current Frequency	50Hz																			
Outside temperature	-40 + 45 C°																			
Impedance voltage	4,5-5,5%																			
2	<p>Complete set of transformer substation of rural type: Complete power transformer substation for outdoor installation; it serves for receiving three-phase current electric power with a frequency of 50 Hz, a voltage of 6 or 10 kV and transforming it into electricity with a voltage of 0.4 kV and supplying it to separate populated locations and industrial facilities.</p> <table border="1"> <tr> <td>Type of transformer</td> <td>Oil, 3 phased</td> </tr> <tr> <td>Power of transformer</td> <td>250 kVA</td> </tr> <tr> <td>Rated voltage at the HV (High Voltage) side</td> <td>6; 10 kV</td> </tr> <tr> <td>Rated voltage at the LV (Low voltage) side</td> <td>0,4 kV</td> </tr> </table>	Type of transformer	Oil, 3 phased	Power of transformer	250 kVA	Rated voltage at the HV (High Voltage) side	6; 10 kV	Rated voltage at the LV (Low voltage) side	0,4 kV	set	1	Takhtakupir district								
Type of transformer	Oil, 3 phased																			
Power of transformer	250 kVA																			
Rated voltage at the HV (High Voltage) side	6; 10 kV																			
Rated voltage at the LV (Low voltage) side	0,4 kV																			

¹ If the total amount differs from the unit price, the unit price prevails and the total amount will be adjusted according to the unit price.

	Current Frequency	50 Hz				
	Outside temperature	-40 + 45 C°				
	Impedance voltage	4,5-5,5 %				
	Types of security: -from phase-to-phase short circuits; -from atmospheric overvoltage; -from overload and short circuits of 0.4 kV lines; -from short circuits of heating circuits, lighting circuits; - gas protection of the transformer;					
	The set additionally includes:					
	1.1. Disconnecter Linear External Double-layer - 1pc.					
	1.2. Automated Energy Accounting System (counter, modem) - 1pc.					
3	Complete set of transformer substation of rural type: Complete power transformer substation for outdoor installation; it serves for receiving three-phase current electric power with a frequency of 50 Hz, a voltage of 6 or 10 kV and transforming it into electricity with a voltage of 0.4 kV and supplying it to separate populated locations and industrial facilities.		set	1	Shumanay district	
	Type of transformer	Oil, 3 phased				
	Power of transformer	100 kVA				
	Rated voltage at the HV (High Voltage) side	6; 10 kV				
	Rated voltage at the LV (Low voltage) side	0,4 kV				
	Current Frequency	50 Hz				
	Outside temperature	-40 + 45 C°				
	Impedance voltage	4,5-5,5 %				
	Types of security: -from phase-to-phase short circuits; -from atmospheric overvoltage; -from overload and short circuits of 0.4 kV lines; -from short circuits of heating circuits, lighting circuits; - gas protection of the transformer;					
	The set additionally includes:					
	1.1. Disconnecter Linear External Double-layer -- 1pc.					
	1.2. Automated Energy Accounting System (counter, modem) - 1pc.					

Delivery addresses:

1. Muynak district, the district center. Muynak branch of electric network, 1A, Berdah street;
2. Shumanay district, the district center. Shumanay branch of electric network, 121, Uzbekistan street;
3. Takhtakupir district, the district center. Takhtakupir branch of electric network, 53, Berdah street.

[Name and Signature of the Supplier's Authorized Person]

[Designation]

[Stamp]

[Date]

TABLE 2: Offer to Comply with Other Conditions and Related Requirements

Other Information pertaining to our Quotation are as follows:	Your Responses		
	<i>Yes, we will comply</i>	<i>No, we cannot comply</i>	<i>If you cannot comply, pls. indicate counter proposal</i>
Delivery Lead Time within 45 calendar days from the date of prepayment (applicable to local companies) or signing of the Contract (applicable to foreign companies)			
Full compliance with the technical specifications requested			
Country/ies Of Origin ² :			
Warranty and After-Sales Requirements			
a) Minimum one (1) year warranty on goods			
b) Services are rendered when it is necessary to repair the delivered equipment in the territory of the Republic of Uzbekistan			
c) Elimination of incompliances during the whole warranty period			
Option a) Replacement with a completely new material(s) if the previously delivered does not meet the standards, norms and is not subject to repair			
Option b) Other (<i>pls, describe</i>)			
Validity of Quotation, 60 calendars days from the date of the bid opening			
All Provisions of the UNDP General Terms and Conditions			

All other information that was not provided by us in the respective Offer, automatically means full compliance with the requirements, deadlines and terms of the Request for Quotation.

[Name and Signature of the Supplier's Authorized Person]
[Designation]
[Stamp]
[Date]

² If the country of origin requires Export License for the goods being procured, or other relevant documents that the country of destination may require, the supplier must submit them to UNDP if awarded the PO/contract.

PART 2: DECLARATION OF INTEREST

Dear Sir/Madam,

We/I, _____ (Name and Title), as shareholder(s)/owner(s) of _____ Company, declare that:

- a) Have no financial and other interests in, association or relationship with, are not employed and do not have relatives (i.e. spouse, parents, children or siblings) employed by the United Nations Development Programme (UNDP) or the Government of Uzbekistan that announced the RFQ; and do not have access to information about, or influence on the selection process for this RFQ
- b) Have no common controlling partner, director, shareholder, legal representative for the purposes of this RFQ with any other entity submitting its Quotation under this RFQ; are not subcontracting or are subcontractors to other entities for the purposes of this RFQ; and that the experts proposed in the team do not participate in more than one Quotation for this RFQ
- c) Are not involved in activities that could have an impact on the objectivity and independence of the Contractor's team in carrying out its duties under the contract or can affect the image of the United Nations and the Government of Uzbekistan.

We certify that the information stated is true, correct and complete to the best of our knowledge and belief. We are obliged to comply with all requests for additional information, documentation, clarification and/or verification concerning the Declaration of Interest statement.

All other information that we have not provided automatically implies our full compliance with the requirements, terms and conditions of the RFQ.

[Name and Signature of the Supplier's Authorized Person]

[Designation]

[Stamp]

[Date]

PART 3: COMPANY PROFILE

1. Offeror's Legal Name <i>[insert Bidder's legal name]</i>		
2. In case of Joint Venture (JV), legal name of each party: <i>[insert legal name of each party in JV]</i>		
3. Actual or intended Country/ies of Registration/Operation: <i>[insert actual or intended Country of Registration]</i>		
4. Year of Registration in its Location: <i>[insert Bidder's year of registration]</i>		
5. Countries of Operation	6. No. of permanent staff in each Country	7. Years of Operation in each Country
8. Legal Address/es in Country/ies of Registration/Operation with contact details ³ : <i>[insert Bidder's legal address in country of registration]</i>		
9. Value and Description of Top two (2) Biggest Contracts for the past three (3) years		
10. Latest Credit Rating (Score and Source, if any)		
11. Brief description of litigation history (disputes, arbitration, claims, etc.), indicating current status and outcomes, if already resolved.		
12. Offeror's Authorized Representative Information Name: <i>[insert Authorized Representative's name]</i> Address: <i>[insert Authorized Representative's Address]</i> Telephone/Fax numbers: <i>[insert Authorized Representative's telephone/fax numbers]</i> Email Address: <i>[insert Authorized Representative's email address]</i>		
13. Are you in the UNPD List 1267.1989 or UN Ineligibility List? <input type="checkbox"/> YES or <input type="checkbox"/> NO		

[Name and Signature of the Supplier's Authorized Person]
[Designation]
[Stamp]
[Date]

³ You must specify address of permanent office, landline telephone numbers

PART 4: EXPERIENCE IN SIMILAR NATURE*

Name of the good supplied	Delivery period (month, year)	Amount of the contract	Client (Name, contact person, telephone, e-mail)

* - At least 3 contracts for the last 3 years for supply of similar goods

[Name and Signature of the Supplier's Authorized Person]
[Designation]
[Stamp]
[Date]