



United Nations Development Programme

ITB-416/18 - Rehabilitation of 200m³/hr. Water Compact Unit-Al Kanhash Village-Al Namrud Sub-District-Al Hamdaniyah District-Ninawa Governorate

Addendum # 1

Date: 21 June 2018

This Addendum is issued with the purpose to amend ITB-416/18 dated June 10, 2018 as follows:

Q1: Reference to items 30, 31 and 32

We would like to inform you that there is no I beam 150 in Russian Standard; it is available in 140 and 160 as shown in attached standard. And annex for IPE is not attached.

A1: The IPE 150 has been changed to IPE 160 in the Civil Work line items 30, 31, and 32. Please note that the steel sections are according to the European Standards. Kindly find the updated/uploaded following documents:

- 1. Revised BoQ as Annex 1A**
- 2. Specifications for Steel Section as Annex 1B**

All other terms of the bidding documents remain unchanged and valid. This Addendum constitutes an integral part of the bidding documents for ITB-416/18.

Yours sincerely,

A handwritten signature in blue ink, which appears to read 'Piero Franceschetti', is written over the typed name and title.

Piero Emanuele Franceschetti
Head of Service Center
UNDP Iraq