



United Nations Development Programme


**ITB-416/18 - Rehabilitation of 200m3/hr. Water Compact Unit-Al Kanhash Village-Al Namrud
Sub-District-Al Hamdaniyah District-Ninawa Governorate**

Addendum # 3

Date: 26 June 2018

This Addendum is issued with the purpose to upload Question and Answers related to ITB-416/18 dated June 10, 2018 as follows:

Q1. Referring to item 33 of the civil works there is a difference in the thickness fixed 3 mm in boq and 5 mm in drawing .. Please indicate correct with appreciation

A1. The thickness should be 5mm. Please find attached the revised thickness uploaded as Annex –  3A

Q2. please check the Mechanical ITEMS 2.2 if the Unit is M3 or M2?

A2. The item unit is in M3

Q3. referring to item 3 from mechanical works, do you mean Accumulation Tank where the sedimentation tank written in item 2 and if the right is Accumulation Tank the dimension must be 6 m x 2.4 x 2.4 m

A3. The dimensions are: 6m x 2.4m x 2.4 m

Q4. We do not know what your opinion about the I beams item

A4. All the IPE 150 changed to IPE 160 as in previous email for the same project

Q5. in item 43 soil excavation for pipe 8" and item 45 polyethylene pipe 4" What is right and what is wrong 4" or 8"

Q6. The excavation is for 4" diameter pipes.

All other terms of the bidding documents remain unchanged and valid. This Addendum constitutes an integral part of the bidding documents for ITB-416/18.

Yours sincerely,


Ijaz Hussain
Head of Procurement, UNDP Iraq