

Date: 28th June 2018

## RESPONSE TO REQUEST FOR CLARIFICATIONS ITB 425/18 REHABILITATION OF BATNAYA WATER DISTRIBUTION NETWORK-TELKAIF- NINAWA GOVERNORATE

Reference is made to the UNDP published procurement notice for the procurement of Rehabilitation of Batnaya Water Distribution Network-Telkaif - Ninawa Governorate on the 11<sup>th</sup> June 2018 on both the UNDP and UNGM websites respectively.

All interested potential bidders are hereby notified that the bid submission deadline has been extended from 1<sup>st</sup> July 2018 to 9<sup>th</sup> July 2018 to allow for preparation and submission of your bids.

Following the site visit, please note that there were clarifications as provided below;

Item No:	Bidders Requests for Clarification	UNDP Response to Bidder's "Request for Clarification"
1	Where is the main feeder damaged line?	The damaged line consists of several intervals spacing between Telkaif pump station and Batnaya town. The main feed pipeline extends in parallel with the electric poles. All damaged line intervals will be determined by the UNDP engineer during the project site preparation period.
2	Where are the interior network paths for the new work?	All new pipeline paths will be for the Southern part of Batnaya town to be implemented under the main streets and sidewalks. All new pipelines paths will be allocated by UNDP project engineer during the project site preparation period.
3	Is the water network design required?	No new design is required, only as built drawing will be submitted after completion of the work

This Addendum I forms an integral part of the ITB-425/18.

All other Terms and Conditions in this ITB will remain unchanged.

Yours sincerely,

Anas Fayyad Qarman
Operations Manager- Service Center