
**ITB-479/18 – Construction of Concrete Reservoir with 5 Wells in Alqosh-Hamdaniah District-
Ninewa Governorate**

QUESTIONS AND ANSWERS

Item No:	BIDDER QUESTION	UNDP RESPONSE
1	BOQ/ in sanitary items we have fuel tank but we have another items 12 in electrical works so is the two tanks required and it will use for generator?	Yes its two type of tanks, the light plate tank is for daily fuel and the second for storage.