

### Question and Answer

#### ITB-284/18-Rehabilitation of Sinjar Cement Substation, Ninawa Governorate

	Question submitted bidders	Answer by Technical Team
1	Please send us the technical specification of the 417kVAR capacitor bank	<p>Due to rehabilitation nature, it is highly recommended to be the same as existing for balance and compatibility with the existing undetected units:</p> <p>Standard: IEC 60871 Type: ALSTHOM/MAXIVAR Cn = 14.988 <math>\mu</math>F Imp: JARYLEC C101 Qn= 417kVAR Un= 9526V Ui=70/170 kV Fn= 50Hz T°=-25/+55°C</p>