



Empowered lives.  
Resilient nations.

Date: 27<sup>th</sup> August 2018

**ADDENDUM 01 - RESPONSE TO REQUEST FOR CLARIFICATIONS:**

**ITB-602-18: Rehabilitation of Nationality and Civil Status Building in Telafer-Ninawa Governorate**


Based on the site visit, following are the Q&A asked during the site visit.

No.	BIDDER QUESTIONS ASKED	UNDP RESPONSES GIVEN
1	What kind of Mosaic tiles for the floor should be used?	Using the same type (#3), size (30cmx30cm) and color of the old mosaic tiles.
2	Does laboratory tests are required?	Yes, they are required. All materials used, and it determined by end user ( sand, cement, Mosaic tiles, ceramic, different type of paint).
3	How to replace the windows?	According to BoQ (repairing steel windows and installing new pvc windows)
4	Shall we remove the damaged furniture in the site?	Yes, in agreement with the end user, the damaged furniture should be removed with the rubble and the debris, and the remain furniture must be put it in the place specified by end user.
5	What is the Contract duration?	The contract duration is 90 Calendar days.

This Addendum - I forms an integral part of the ITB -602/18.

**All other Terms and Conditions in this ITB will remain unchanged.**

Yours sincerely,

  
Piero Emanuele Franceschetti  
Head of Service Center, Iraq