

Bid Bulletin 1

IRQ-RFQ/668-18

Rehabilitation work for Sada Al-Iraq school in Touz

Site Visit Questions and Answers

Q1) Does the cracks repair include use of any additive?

A) Yes, the contractor required to use Styrene-Butadiene Rubber (SBR).

Q2) What is the height of preliminary coating and skirting?

A) The height is 1.3 meter