Site Visit Report

ITB No: IRQ-RFQ/ 669-18 Rehabilitation of Yafa Primary School in Al-Touz - Salahdien Governorate		Date of Site Visit 6th Sep. 2018		Escorted by Military Forces YES☐, NO ☒
Time of Site Visit		Name(s) and job title of Gov. Rep.		
Start	End			
12:00	12:45			

Names of companies attended	Rep. name	Mobile/Email	Signature
1- IPEK Energy Indostry And Trade INC. Co	HASAN RASRI SENAC	00905322782080	

QUESTIONS AND ANSWERS

No.	BIDDER QUESTIONS ASKED	UNDP RESPONSES GIVEN
1	Is there any drawing of Handrails	Yes There is drawing of handrails, height (1.5m)
2	The Thickness of walkways Casting	The thickness of Walkways Casting (12 Cm)
3		
4		
5		
6		
7		

Attendance sheet for the bidders who visited the sites:

Photos during the site visit for the current situation: Attached

The authorized focal person responsible for preparing attendance sheets before the site visit and photography

Certification of Minutes as a true record of the proceedings of the meeting/site visit:

Prepared by:

Loqman hasan Ahmed

Signature: Position: Al-Touz site Engineer Date: 06th Sep, 2018

Record of Pre-Bid Meeting/site visit to be posted on the websites.