

Bid Bulletin 1

IRQ-ITB-632/18

Reconstruction of New Baiji Police Station Building - Salahuddin Governorate

Questions & Answers

Q1) what is the degree of the compaction for the item # 1?

A) the degree of compaction as indicated in the BoQ should be 95%

Q2) what is the width of strip footing excavation for the item # 2?

A) the width as indicated in the BoQ should be 100 cm

Q3) what is the thickened of the sub-base layer for the item# 3?

A) the thickness as indicated in the BoQ should not be exceed 15 cm.

Q4) what kind of cement which is used for the item # 7?

A) the cement type as indicated in the BoQ should be sulfate resistant with sika proof

Q5) what is the size of ceramic required for the item # 22?

A) the ceramic size as indicated in the BoQ 30X30 cm None Slip.

Q6) what kind of pipes required for the item # 1 under sanitary?

A) the pipes details as indicated in the BoQ should be 4" P.V.C, 6 bar atmospheric pressure.