

Bid Bulletin 2

IRQ-ITB-632/18

**Reconstruction of New Baiji Police Station Building - Salahuddin
Governorate**

Please note that the power capacity for the gen set (Item # 12 – electrical works on the BOQ) remained as indicated in the BOQ (150KVA), while the old compliance sheet was indicated (100KVA) now the compliance sheet has been updated accordingly to reflect this change.

The bidder should quote their price according to the BoQ (150 KVA).