

Question and Answer

ITB-663/18-Rehabilitation and Stringing for 33kv single circuit Over Head Transmission in Ninewa Governorate

	Question submitted bidders	Answer by Technical Team
1	<p>Regarding Item # 1-C; Earthing system. Please provide details/diagram indicating in it the connection of Copper cable 1x50mm² for each pole with it's copper earth rod.</p> <p>Furthermore; the Copper cable 1x50mm² will be connected for each pole, where on pole? Please specify it?</p>	<p>Ref. to Iraqi technical specifications of Tubular steel poles shown on annex-2 already attached with this BoQ, for earthing purposes a (20mm)dia. hole shall be drilled at the bottom of each pole at a distance of (15cm) under ground level with a suitable length (M-18) galvanized bolt, nut and washer shall be supplied with each pole.</p>