

Question and Answer

ITB-665/18-Rehabilitation of Heavy Truck Maintenance & Carpentry Factory, East Mosul, Ninawa Governorate

	Question submitted bidders	Answer by Technical/Procurement Team
1	According to attached file "ITB_665_18-TCS-Mechanical-28082018", requested crane duty specification is M7(class3). However cranes that will be used in workshops should be M4 or less. In this case M7 requirement is not necessary.Please clarify which class we need to choose.	The crane size is what was required by the end user and can not be changed.
2	Please clarify the specification of substation which contains RMU,transformer and LV panel. / Please provide the layout plan that show the location of RMU ,electrical poles and 2 each Main Board.	The specifications of RMU and transformer are explained in (D-07 Ring main unit & D-26 Distribution transformer).
3	Please clarify if fire alarm and mass notification system required for this project. If yes please provide the drawings and spesifications.	Fire alarm and mass notification are not required.

4	Please provide the specification of Low voltage panels.	The low voltage panels are specified with in the item description of BoQ.
5	Please provide the layout plan of grounding system.	The layout plan of grounding is shown in the drawings.
6	Please clarify if the lightning protection system required for this project. If yes please provide the drawings and specifications.	Lightening protection is not required.
7	Please provide the distances between communication centre and construction area where OSP(outdoor FO and copper cables) cables to be connected.	There is no communication center, this may be done in the future. The item is just for future expansion.
8	Please provide the drawings and specifications of telecommunication system.	There is no communication center, this may be done in the future. The item is just for future expansion.
9	Could you please provide us “Event Details Document” for bid submission.	Event Details Submission will be generated once you post your offer.

10	We are requesting a time extension to bid due date.	UNDP does not have any intention to extend the deadline at this point.
----	---	--