

Minutes of the Pre-bid meeting held on September 16, 2018
For Supply, installation, configuration, spare parts and Hardware maintenance of Database high end server

Date: September 18, 2018

Members attended the meeting:

Name	Designation
Shamsun Nahar Airin	Procurement Associate, UNDP
Debabrata Sarkar	Data Center Expert, a2i
Arfe Elahi Manik	CTO, a2i
Bidders	As per attached Attendance sheet.

With reference to the subject ITB issued on September 9, 2018, please find below the queries raised by Invitees and answers thereto from UNDP Bangladesh:

SL	Queries	Answers
1	Is it possible to increase the proposal submission deadline?	No
2	Is it mandatory to fulfil the minimum eligibility criteria?	Yes.
3	Page no. 22, is it possible to revise Dimension: 1070mm x 600mm x 42U (DxWxH), Instead of 1075mm x 600mm x 42U (DxWxH),	Bidder may offer with the changed dimension along with manufacturer's product document/brochure
4	Page no. 23, is it possible to revise Dynamic load: At least 2050 lbs. instead of At least 2500 lbs.	Bidder may offer with the changed Dynamic load value along with manufacturer's product Document/brochure
5	Page no. 23, Networks (s:n-8): is it possible to revise Performance: 10 Gbps Latency: < 2.5 μ s (64-byte packets) instead of 10 Gbps Latency: < 1.5 μ s (64-byte packets).	Amendment: 10 Gbps Latency: < 2.5 μ s (64-byte packets). However, optimized latency will also be accepted.
6	For all server item no: 6, is it required?	Yes
7	Page no. 23, Firewall Server (s:n-9): is it possible to revise Memory: 32GB (2 x 16GB dual-rank RDIMM) 2666 MT/s DDR4 instead of 32GB (1 x 16GB dual-rank RDIMM) 2666 MT/s DDR4	Amendment: 32GB (2 x 16GB dual-rank RDIMM) 2666 MT/s DDR4
8	Page no: 45: detail BoQ/technical specification required for S:N: 8 and 9 to quote	For Electrical Works: Connectivity Limited to Industrial Socket on nearest rack isle. For Network Cable: Limited to DC Access switch uplink establishment through fiber and full rack CAT6 cabling as per purchaser's network plan for minimum 5 network interfaces of each server.

Minutes of the Pre-bid meeting held on September 16, 2018
For Supply, installation, configuration, spare parts and Hardware maintenance of Database high end server

9	Page no. 28, S: N-3, Processor: 7 th generation is out of production therefore, is it possible to quote for 8 th generation?	Updated Generation CPU will be accepted
10	How many distribution boards required?	Not Applicable
11	Is main cable for this distribution board include?	Not Applicable
12	Do we include surge suppressor price?	Not Applicable
13	Do we include earthling price? is boring required?	Not Applicable
14	Is cable tray required?	Optional
15	Can bidder submit through sealed envelope to your stipulated address?	e-tendering system must be used for bid submission.

Note: Above Clarifications in response to queries raised during the Pre-bid meeting and amendments shall be an integral part of the RFP document and supersede the all provisions as applicable.