

Question and Answer

ITB-663/18-Rehabilitation and Stringing for 33kv single circuit Over Head Transmission in Ninewa Governorate

	Question submitted bidders	Answer by Technical Team
1	We have one clarification about cable 3x150 33KV specification, in the GTP compliance sheet the required specification for the Outer sheath is Black while in MoE iraq specification (D-03 specification Page 5 Article 6.10.b) the color must be RED, Please advice what Outer Sheath color is required for this cable in this Tender.	The required 33 kV cables color shall be RED.