

---

RFQ-714/18 - Installation of 400 V UG Cable - Women education faculty-Mosul University  
East Mosul.

**QUESTIONS AND ANSWERS During the site visit**

No.	BIDDER QUESTIONS ASKED	UNDP RESPONSES GIVEN
1	Can we use cable tray for (3x70+35)mm2 power cable	Yes, whenever you find a suitable path