

INVITATION TO BID

UNDP CYP ITB 103 2018

CONSERVATION WORKS OF THE AGIOS ANDRONICOS CHURCH

Clarifications no:1 dated 29 November 2018

| | QUERY | CLARIFICATION |
|-----|---|---|
| Q1 | Would a total value of one similar executed Project with a cost of more than 650,000 Euro satisfy the previous relevant experience criteria? | The technical requirement is specified; bidders are to submit information on projects they deem relevant. We always encourage formation of consortiums to meet the administrative and technical requirements. |
| Q2 | - DRWG P04 The roof section to be permanently supported at both EAST & WEST PORTIONS whereas in DRWG CW02 LATERAL SECTION SHOWS ONLY the EAST section . Please clarify whether the west portion also to be supported. | DRWG P03 shows clearly that east and west portions of the roof shall be supported. |
| Q3 | Would steel system can be used instead of timber sections. | At this stage of the tender changes of materials will not be considered. Bidders have to prepare whatever is specified in the specifications, bills and drawings. |
| Q4 | Would temporary supports also can be made of steel components | Same reply as above for Q3. |
| Q5 | SD01 States the external fencing system to be repaired , whereas no mention either in BOQ and Technical Specifications. Please clarify. | Please price the bills as they are. |
| Q6 | Technical Specification page 16; F 6.0 Formwork (permanent supports). Quote: "Unless specifically stated otherwise, sizes shown on drawings are finished sized and..... whereas no sizes can be found on the drawings. Please clarify. | The Bills is revised to include a Provisional Sum amount of Euro 15,000 for the supports temporary and permanent as per the drawings. Please see Revision no:1 dated 29 November 2018. |
| Q7 | BOQ page 4 3.ROOF K.11.0 / N.14.0 description: "The existing roof section should temporarily be supported and secured by scaffolds to prevent a future collapse and ensure both the stability and integrity of the roof as well as visitor safety." Please clarify whether the permanent scaffolding also included in this item. | |
| Q8 | There are secant piles shown in Drawing No: S.D.01 to construct but not shown in BOQ? | Please price the bills as they are. |
| Q9 | Technical Specs.P43 refer to the Geo Investigation in parallel with BOQ 9 EXTERNAL Works Item 5. Please clarify whether the drawings SD01 and SD02 showing all structural details for the secant piling will be executed or not, if so there is no item for such work in the BOQ. | The geotechnical investigations will be done for the stipulated parameters. There is no execution of the piling. |
| Q10 | In Drawing No.: P02 a drainage system is shown but not included in BOQ | There is a provisional sum amount of Euro 5,000 for the drainage. |
| Q11 | In Drawing No. P14 there is a south elevation door to be constructed but not shown in BOQ | BoQ Item 6.2 covers the south elevation door. |
| Q12 | In drawing CW02, we can see permanent scaffolding system. However, we have not seen such item in either BoQ or in the technical specifications. Hence we are unable to price the item. | Please refer to the clarification provided for Q6 and Q7. |
| Q13 | In drawings SD01 and SD02 we can see secant pilings. However, we have not seen such item in either BoQ or in | Please price the bills as they are. |

| | | | | | | | |
|-----|--|--|--------|------------------------------------|---|------|--|
| | the technical specifications. Hence we are unable to price the item | | | | | | |
| Q14 | The submission deadline is clashing with Arsenal project . We will highly appreciate it if you could extent the submission at least for 10 days? | The submission deadline will not change. | | | | | |
| Q15 | we want to prepare an offer for Agios Andronikos church and we would like to visit the church and see "in situ" the wall paintings and the historical mortars. It is possible someone to open the church for us? | The church is accessible. | | | | | |
| Q16 | Conservation Works of the Agios Andronicos Church - mesh in apse up the main North entrance What is meant by the BOQ item below not understood, where is this please clarify? 6. Windows and Doors <table border="1" data-bbox="228 678 859 774"> <tr> <td>3</td> <td>M.13.8</td> <td>In apse up the main North entrance</td> <td>1</td> <td>Item</td> </tr> </table> | 3 | M.13.8 | In apse up the main North entrance | 1 | Item | Technical specifications, page 44 article 13.8 describes what is required. |
| 3 | M.13.8 | In apse up the main North entrance | 1 | Item | | | |
| Q17 | Conservation Works of the Agios Andronicos Church - Permanent scaffolding. The BOQ item below says that there is a temporary scaffolding to be set up inside the church however drawings showing that scaffolding is to be permanent. Could you please clarify? | Please refer to the clarification provided for Q6 and Q7, please also note that scaffolding is not mentioned in the BoQ. | | | | | |