

Question and Answer No. 4

ITB-804/18-Rehabilitation of Ibn Al Atheer Hospital Building, East Mosul, Ninewa Governorate

No.	Question submitted by bidders	Answer by Technical and Procurement Teams
1	If you have a Phasing Plan for this project, could you please publish it?	After agreement with the end user, a work plan is prepared and the rehabilitation works will be done in two stages described briefly that guarantees providing services during the rehabilitation, but it is the contractor's responsibility to develop the work plan in detail on the proposed work plan and get approval from UNDP and the end user before commencement of the works.
2	ITB_804_18-BOQ-30122018"Mechanical Item#17: Could be used European standard black steel pipe instead of schedule 40 pipe?	No.
3	ITB_804_18-BOQ-30122018"Arc.&Civil, Item#3: According to item 3 , required paint is anti bacteria oil paint. We think that must be antibacterial acrylic paint . Could you please clarify.	The required paint is anti-bacterial oil paint.
4	The last section of the BOQ's General Notes state the following: "The bidders need to consider the cost of any temporary works needed to keep the hospital working during the renovation works, works like the following below but not limited to".	More detail will be provided and the revised BoQ will be shared in an amendment.

5	<p>Would you please provide me with some details regarding the CCTV System as Below :</p> <ul style="list-style-type: none"> -Number of channels you want to have. -The distance between the control room and the farthest place that should be controlled or the number of floors in the building and the number of rooms within each floor. 	<p>Number of inputs cameras of NVRs shall be at least 16 IP inputs.</p> <p>CCTV cameras is an IP-based meaning Each camera shall be connected to the related communication cabinet in the same department through cat6a cable (cat6a cable shall not run more 90m).</p>
6	<p>Reference to up mentioned ITB, we are asking if you can consider the similar project for 10 years same to what happened in Falluja and Ramadi Hospitals, because as you know, there are no hospital project completed in Iraq since 6 years ago and the companies that have completed similar project in 7 years is very limited may be one or two.</p>	<p>We are considering revision of the requirements. If it concludes positively, it will be shared in an amendment.</p>