

IRQ-ITB-009/19 - Supply of valves for Al Qubba Water Treatment Plant, East Mosul  
Ninawa Governorate, Iraq

**QUESTIONS AND ANSWERS**

**RECORDED DURING SITE VISIT HELD ON 23 JANUARY 2019**

No.	BIDDER QUESTIONS ASKED	UNDP RESPONSES GIVEN
1	<b>Is the pressure resistance of the valves PN 4 or PN 10</b>	<b>The pressure resistance of valves PN10</b>
2	<b>The used valve in the back was is butterfly valve or gate valve</b>	<b>All valves are GATE valves as indicated in the BOQ</b>

**QUESTIONS AND ANSWERS - via E-MAIL**

3	Pls. confirm the length of valve stem is Germany standard (DIN 3352-F4) or UK Standard (BS5163).	The length of valve stem is German standard (DIN 3352-F4).
4	We would like to ask you about the term and condition for making Joint Venture. Can we submit the ITB009/19 as the Joint Venture?	Kindly refer to clause 14. Joint Venture, Consortium or Association on page 9 of the ITB-009/19 and fill Form C: Joint Venture/Consortium/Association Information Form and attach the JV agreement which spells out each party's responsibility.
5	Does our price need to include installation of the valves?	No
6	Do you have any minimum number for the workers (skilled / unskilled) which we need to use for the project?	The subject project is only supply and no installation is required. Thus, no requirement for the workers.
7	The company established in 2018 and in order to qualify the requirements, can we participate with other firm	Kindly refer to the requirements for the bidder (either individual company or joint venture) on the ITB-009/19 which explicitly spelled out the requirements/criteria along with required documentations
8	Does it accepted to quote for butterfly valves instead of gate valves for this project as for the filter and back wash application butterfly valves technically better.	No As per tender rules, the offer is to be submitted as per the announced technical specs, i.e. BOQ, compliance sheet, etc. which indicates GATE valves
9	Do we required to provide manufacturer authorization	The manufacturer's authorization is required if the supplier is not manufacturer It is required to indicate how the warranty will operate in Iraq Additionally manufacturer's certification and other technical documents are required as per compliance sheet