


13 February 2019

UNDP's RESPONSES TO SUPPLIERS' QUESTIONS

RFQ for the Supply and Delivery of Roofing Materials to Dominica

Bid Submission Deadline: Extended to 25 February 2019, 5p.m. AST

No.	Question	UNDP Response
1	<i>Item 1 : Z Purlins, 5x2", 16 gage (0.0598"), galvanized, 20' lengths: please confirm that the unit of measurement (2000 lf) refers to "long foot", that is, 100 polines type Z.</i>	UNDP estimates it will need 2000 linear feet of type Z purlins. UNDP has stated a preference for 20-foot lengths but will accept other lengths. Prices should be quoted as per length. Payment will be based on the final amount indicated on the purchase order issued to the successful bidder.
2	<i>Item 3 : Corrugated Metal Roofing, 0.034" Steel Thickness, G90 (0.45 oz/sf) galvanized coating, paint finish. There is no information about the measures or quantities. Could you provide us this information?</i>	Note that on the bid sheet items 4 and 5 are 3a and 3b. This correction has been noted in responses posted previously.
3	<i>Item 4 : 17' lengths (net coverage with 9" lap): Could you please clarify what is a net "coverage with 9" lap. Do you have more technical specifications? It is any kind of net? Which is their function? The unit of measurement (6300 sf) refers to "ft²"</i> <i>Item 5: 13' lengths (net coverage with 9" lap): Could you please clarify what is a net "coverage with 9" lap. Do you have more technical specifications? It is any kind of net? Which is their function? The unit of measurement (5500 sf) refers to "ft²"</i>	For both items 4 and 5 the area to be roofed is given in square feet, 6300 and 5500 respectively. Sheeting will overlap 4 ½ inches on both sides. For example, a 42-inch-wide sheet would have a net width of 33 inches. UNDP has specified the lengths required but will accept varying widths. Payment will be per net square feet.
4	<i>Item: 6 : Ridge Cap. 24" wide, match roofing, 20-degree brake: Please clarify the ridge cap measures.</i>	
5	<i>Item 8 : #10 x 2" Galvanized Screws, Phillips or hex head, 100 ct: Please clarify what does "100 ct" means?</i>	100 count, total of 400 screws

6	<p>"We can supply the roof panels, and the ridge cap. However, the specifications do not specify the paint finish.</p> <p>Do you know if the panels need a factory finish? If not, we can quote a bare galvanized panel."</p>	<p>UNDP is specifying a factory finish. A final selection of color has not been made. Colors under consideration are maroon, white, or grey. Please indicate colors available at your quoted price.</p>
7.	<p>We are interested to participate in subjected tender but delivery time is only 21 days which is not possible. We request you to kindly extend the delivery time from 21 days to 45 day</p>	<p>Failure to meet the Delivery time may cause UNDP to reject the bid. However, under the circumstance where majority or all otherwise compliant bidders are unable to meet this timeframe, UNDP may consider accepting bids with (reasonably) longer delivery periods.</p>
8.	<p>Taking into account the importance of the clarifications requested, we would like to request an extension for the deadline of the submission of this bid.</p>	<p>The bid submission deadline was extended from 18 February 2019 to 25 February 2019, 5p.m. AST.</p>