

# Site Visit Report



<b>ITB No.</b> RFQ-035-19 Rehabilitation and Stringing for 33kV Single circuit Over Head Transmission Line between (Qaraqush 132kV SS) and (Khazir 33kV SS) in Ninewa Governorate.		<b>Date of Site Visit</b>	17 <sup>th</sup> February 2019	<b>Escorted by Military forces?</b>	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
<b>Time of Site Visit</b>		Name(s) and job title of Gov. Rep.			
<b>Start</b>	<b>End</b>				
10:00 AM	12:00 PM.	Eng. Maan Elyas Khdir	Director head of Hamdania electricity	07719637194	
<b>Names of companies attended</b>		<b>Rep. name</b>		<b>Mobile/Email</b>	<b>Signature</b>
Shandz company		Mezher Hussain		Mizher_hussain@yahoo.com	
Kasnazan company		Muhammad Khdir		kasnazancom@yahoo.com 07719674079	
Altik co.		Fatih Atamar		Eser.ataman@altekyapimarket.com.tr 07504649916	
Piril company		Sadettin Akdemir		fatih.atamane@piril.com.tr 07503021201	
TL company		Kanaan Adil		son@tlgrup.com 07507010555	
Hero company		Barz Wahid		barzwahid@hero-contracting.com 07706979541	
Srabal-hadeeth		Fahd Ali Najm		noc@srabal-hadeeth.com	Just he Call
Al- Hamid company		Dhirar		dhirar@alhamidgrup-iq.com	Just he sent an Email

## Site Visit Report



ITB No. RFQ-035-19 Rehabilitation and stringing for 33kV single circuit overhead Transmission Line between Qarefah-Khazir		Date of Site Visit	17th February 2019	Escorted by Military forces?		Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
Time of Site Visit		Name(s) and job title of Gov. Rep.				
Start	End					
10:00 Am	12:00	Eng. Maan El Yasi Khidir	Director head of Mandana electricity	0771963 7194		
Names of companies attended		Rep. name	Mobile/Email	Signature		
ShandZ company		Mezher Hussain	mizher_hussain@xahoo.com			
Kasnazar company		Muhammd Khdir	0771967 4079 Kasnazar.com			
Fatih Al Altek Co.		Fatih Ataman	07504649916	 user.atamane@attetyupimarket.com.tr		
Piril Company		Sadettin Akdeniz	0750 302120	 Fatih.atamane@Piril.com.tr		
TL company		Kanaan Adil	07507010555	 Soni@tlgrup.com		
Hero company		Barz Walid	0750 697 9541	 Barzwalid@hero-contracting.com		
Srabal-hadeeth		Fahd Ali Najm	07701891310	Just Calling		
Al-Hamid company		Dhirar	noc@srabal-hadeeth.com dhirar@alhamidgroup-14.com	Just sent email-		

### QUESTIONS AND ANSWERS

No.	BIDDER QUESTIONS ASKED	UNDP RESPONSES GIVEN
1		
2		

Attendance sheet for the bidders who visited the sites: \*\*\*

Photos during the site visit for the current situation\*\*\*

\*\*\* The authorized focal person responsible for preparing attendance sheets before the site visit and photography

Certification of Minutes as a true record of the proceedings of the meeting/site visit:

Prepared by:

Signature: Name: Saleem A. Saleem Position: Elec Engineer Date: 17th February 2019  
Record of Pre-Bid Meeting/site visit to be posted on the websites.

## QUESTIONS AND ANSWERS

No.	BIDDER QUESTIONS ASKED	UNDP RESPONSES GIVEN
1	With reference to item 1 of the BoQ, On what the design of the profile for the line is depend?	We recommend to use the standard edition of PLS-CADD program which it is a line design program that includes all the terrain, sag-tension, loads, clearances and drafting functions necessary for the design of an entire power line.
2	How many the distance of the OHTL to check it and to make general maintenance of it according to item number 14 of the BoQ?	The 33kV overhead transmission line route starts from the beginning of the line at (132kV Qaraqush Substation) to the (33kV Khazir substation) for a distance of total approx.16km length and partially it is damaged.
3	Do supply and install for missing members and bolts of the tower body include to this BoQ?	Mechanical capacity check shall be done for all of existing towers before starting of stringing, including supply and install of missing members especially for lower part of the Tower body, supply and install of different sizes of bolts and tightening of bolts for some of safe existing 33kV Towers. Supplying of missing members and bolts shall be according to tower drawings or matching with dimensions of exist towers. Supply and installing missing parts and redundant members will be calculate according to item no.14 of the BoQ to energize the line property.
4	On which tower the load break switch will be install?	The load break switch shall be installed on a terminal tower either in front of Khazir 33kV substation or in front of Qaraqush substation according to the final decision from the end user in the ministry of electricity.
5	Does the line route is safe for working?	Small Part 10% of the mentioned line expected contained with a minefield. Cleaning area shall be done before starting any activity there. UNMAS or Iraqi military engineering effort or any other organization may help to clean that area.















Prepared by:

Name: Saleem A. Saleem

Position: Electrical Engineer

Date: 17<sup>th</sup> February 2019