

Amendment No. 1
TO REQUEST FOR QUOTATION FOR LOW-VALUE GOODS

Date: February 21, 2019
Regarding: RFQ/010/19 – Supply of power transformers to Karakalpakstan

This Amendment is submitted to RFQ/010/19 announced on February 14, 2019, for the "Supply of electrical power transformers to Karakalpakstan"

Changes are as follows:

1. "Description and specification of goods" is revised and to be read as stipulated in Annex No. 1 below, which is an integral part of this Amendment No. 1.
2. "Bid Submission Form» is revised and to be read as stipulated in Annex No. 2 below, which is an integral part of this Amendment No. 1.

All Amendments to the RFQ/010/19 are an integral part of it, and all participants must comply with the requirements stipulated by such additions. Any deviation from the claims made by amendments to this RFQ may result in consideration of the proposal as not meeting the requirements and withdrawing from further evaluation.

All other terms and conditions of the RFQ/010/19 remain unchanged.

№	Description and specification of goods	UOM	Q-ty	Delivery address	
1	Complete set of transformer substation of rural type: Complete power transformer substation for outdoor installation; it serves for receiving three-phase current electric power with a frequency of 50 Hz, a voltage of 10 kV and transforming it into electricity with a voltage of 0.4 kV and supplying it to separate populated locations and industrial facilities.	Set	6	Muynak district – 3 sets; Takhtakupir district – 2 sets; Shumanay district – 1 set	
	Type of transformer				Oil, 3 phased
	Power of transformer				250 kVA
	Rated voltage at the HV (High Voltage) side				10 kV
	Rated voltage at the LV (Low voltage) side				0,4 kV
	Current Frequency				50Hz
	Outside temperature				-40 + 45 C°
	Impedance voltage				4,5-5,5%
	Types of security: - from phase-to-phase short circuits; - from atmospheric overvoltage; - from overload and short circuits of 0.4 kV lines; - from short circuits of heating circuits, lighting circuits				
	The set additionally includes:				
	1.1. Disconnecter Linear External Double-layer				1pc.
	1.2. Metering system ASKUE (metering panel consisting of: GPRS-modem, power supply, automatic switch, metering device, SIM-card, current transformer)				1pc.
	2				Complete set of transformer substation of rural type: Complete power transformer substation for outdoor installation; it serves for receiving three-phase current electric power with a frequency of 50 Hz, a voltage of 10 kV and transforming it into electricity with a voltage of 0.4 kV and supplying it to separate populated locations and industrial facilities.
Type of transformer		Oil, 3 phased			
Power of transformer		160 kVA			
Rated voltage at the HV (High Voltage) side		10 kV			
Rated voltage at the LV (Low voltage) side		0,4 kV			
Current Frequency		50 Hz			
Outside temperature		-40 + 45 C°			
Impedance voltage		4,5-5,5 %			
Types of security: -from phase-to-phase short circuits; -from atmospheric overvoltage; -from overload and short circuits of 0.4 kV lines; -from short circuits of heating circuits, lighting circuits					
The set additionally includes:					
1.1. Disconnecter Linear External Double-layer		1pc.			
1.2. Metering system ASKUE (metering panel consisting of: GPRS-modem, power supply, automatic switch, metering device, SIM-card, current transformer)		1pc.			

FORM FOR SUBMITTING SUPPLIER'S QUOTATION

(This Form must be submitted only using the Supplier's Official Letterhead/Stationery)

We, the undersigned, hereby offer to supply the items listed below in conformity with the technical specifications and requirements of UNDP as per RFQ Reference No. RFQ/010/19.

Nº	Description and specification of goods	UOM	Q-ty	Delivery address	Unit price (currency) ¹	Total price (currency)
1	Complete set of transformer substation of rural type: Complete power transformer substation for outdoor installation; it serves for receiving three-phase current electric power with a frequency of 50 Hz, a voltage of 10 kV and transforming it into electricity with a voltage of 0.4 kV and supplying it to separate populated locations and industrial facilities.	Set	6	Muynak district – 3 sets; Takhtakupir district – 2 sets; Shumanay district – 1 set		
	Type of transformer					
	Power of transformer					
	Rated voltage at the HV (High Voltage) side					
	Rated voltage at the LV (Low voltage) side					
	Current Frequency					
	Outside temperature					
	Impedance voltage					
	Types of security: - from phase-to-phase short circuits; - from atmospheric overvoltage; - from overload and short circuits of 0.4 kV lines; - from short circuits of heating circuits, lighting circuits					
	The set additionally includes:					
2	1.1. Disconnecter Linear External Double-layer	Set	1	Shumanay district		
	1.2. Metering system ASKUE (metering panel consisting of: GPRS-modem, power supply, automatic switch, metering device, SIM-card, current transformer)					
	Complete set of transformer substation of rural type: Complete power transformer substation for outdoor installation; it serves for receiving three-phase current electric power with a frequency of 50 Hz, a voltage of 10 kV and transforming it into electricity with a voltage of 0.4 kV and supplying it to separate populated locations and industrial facilities.	Set	1	Shumanay district		
	Type of transformer					

¹ If the total amount differs from the unit price, the unit price prevails and the total amount will be adjusted according to the unit price

Power of transformer	160 kVA					
Rated voltage at the HV (High Voltage) side	10 kV					
Rated voltage at the LV (Low voltage) side	0,4 kV					
Current Frequency	50 Hz					
Outside temperature	-40 + 45 C°					
Impedance voltage	4,5-5,5 %					
Types of security: -from phase-to-phase short circuits; -from atmospheric overvoltage; -from overload and short circuits of 0.4 kV lines; -from short circuits of heating circuits, lighting circuits						
The set additionally includes:						
1.1. Disconnecter Linear External Double-layer	1pc.					
1.2. Metering system ASKUE (metering panel consisting of: GPRS-modem, power supply, automatic switch, metering device, SIM-card, current transformer)	1pc.					
Total price of equipment						
Transportation price (three places of delivery)						
Insurance cost						
Other costs (if applicable)						
Total VAT exclusive amount						

Delivery addresses:

1. Muynak district, the district center. Muynak branch of electric network, 1A, Berdah street;
2. Shumanay district, the district center. Shumanay branch of electric network, 121, Uzbekistan street;
3. Takhtakupir district, the district center. Takhtakupir branch of electric network, 53, Berdah street.

UNDP Requirements	Bidder's Response
Validity of Offer: <input checked="" type="checkbox"/> 60 days In exceptional circumstances, UNDP may request the Offeror to extend the validity of the Quotation beyond what has been initially indicated in this RFQ. In such case the extension shall be confirmed in writing, without any modification whatsoever of the Quotation.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Please explain in case of "No": _____
Warranty Period Offered (as applicable): not less than 12 months	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Please explain in case of "No": _____
Description of Warranty Coverage (as applicable): Standard manufacturer's Warranty	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Please explain in case of "No": _____
Description of After Sales Service (as applicable): <input checked="" type="checkbox"/> Warranty on Parts and Labor for minimum period of 12 months <input checked="" type="checkbox"/> Technical Support <input checked="" type="checkbox"/> Provision of Service Unit when pulled out for	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Please explain in case of "No": _____

maintenance/ repair <input checked="" type="checkbox"/> Others: exchange for new similar product on any item if found not in operation after delivery by Vendor	
Delivery Terms (linked to INCOTERMS 2010): <input type="checkbox"/> FCA <input type="checkbox"/> CPT <input type="checkbox"/> CIP Tashkent <input checked="" type="checkbox"/> DAP-Karakalpakstan (delivery addresses are below), or <input checked="" type="checkbox"/> DDP-Karakalpakstan (delivery addresses are below) Customs clearance ² , if needed, shall be done by UNDP Uzbekistan	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Please explain in case of “No”: _____
Payment Terms: To Local Supplier (registered in Uzbekistan): <input checked="" type="checkbox"/> Will be made in Uzbek Soum in two installments: (1) 15% advance payment upon signature of Contract by the sides; and (2) 85% final payment upon provision of Protocol of Testing per each equipment by the Supplier, after signature of Acceptance Certificate of Equipment and tax-invoice by the parties. To Foreign Suppliers (registered outside Uzbekistan): <input checked="" type="checkbox"/> Will be made in USD as 100% post-payment upon provision of Protocol of Testing per each equipment by the Supplier, delivery of all the equipment to the destination places and signature of Acceptance Certificate of Equipment by the parties.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Please explain in case of “No”: _____
Delivery terms: Applicable to local Companies: Within 45 calendar days from the date of prepayment receipt. Applicable to foreign companies: Within 60 calendar days from the date of Contract signature by the sides. Attention: If the delivery period, stated in the quotation exceeds the delivery period stated above, the respective offer may be declined!	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Please explain in case of “No”: _____
All documentations, including catalogs, instructions and operating manuals, shall be in: <input checked="" type="checkbox"/> English <input type="checkbox"/> French <input type="checkbox"/> Spanish <input checked="" type="checkbox"/> Russian	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Please explain in case of “No”: _____
Liquidated Damages: <input type="checkbox"/> Will not be imposed <input checked="" type="checkbox"/> Will be imposed under the following conditions: Percentage of contract price per day of delay: 0.5%. Max. no. of days of delay: 15 calendar days. After which UNDP may terminate the contract.	<input type="checkbox"/> Accept <input type="checkbox"/> Does not accept <input type="checkbox"/> Please explain in case of “Does not accept”: _____
Please confirm that your company is not included in the UN Security Council 1267/1989 list, UN Procurement Division List or other UN Ineligibility List;	<input type="checkbox"/> Not listed <input type="checkbox"/> Listed <input type="checkbox"/> Please explain in case of “Listed”: _____

² Must be linked to INCO Terms chosen

Please confirm that you accept the UN Supplier Code of Conduct, https://www.un.org/Depts/ptd/about-us/un-supplier-code-conduct	<input type="checkbox"/> Accept <input type="checkbox"/> Does not accept <input type="checkbox"/> Please explain in case of “Does not accept”: _____
Offeror’s Legal Name <i>[insert Bidder’s legal name]</i>	
Legal Address in the Country of Registration: <i>[insert Bidder’s legal address in country of registration]</i>	
Offeror’s Authorized Representative Information Name: <i>[insert Authorized Representative’s name]</i> Address: <i>[insert Authorized Representative’s Address]</i> Telephone/Fax numbers: <i>[insert Authorized Representative’s telephone/fax numbers]</i> Email Address: <i>[insert Authorized Representative’s email address]</i>	

[Name and Signature of the Supplier’s Authorized Person]
[Designation]
[Date]