

### Question and Answer No. 9

ITB-804/18-Rehabilitation of Ibn Al Atheer Hospital Building, East Mosul, Ninewa Governorate

No.	Question submitted by bidders	Answer by Technical and Procurement Teams
1	<p>Please note the subject matter refers to the Drawing: AR-105 Sheet No: MED-03, the related BOQ: ITB_804_18-BOQ Amendments_NO_1-24012019 and the ITB_804_18-SOW-Amendments_No_1-24012019. Point (5) Works on Brief “adding two Endoscopic Rooms instead of operation theaters”.</p> <p>The rooms in question are: Endoscopy 1 Endoscopy 2</p> <p>The above BOQ and the related drawings call for a Pos. #10 Operation theater Pendant OPERATION THEATER “Surgery Pendant” 2 Units Pos. #11 Operation Theater “Anaesthetic Pendant” 2Units</p> <p>Further, it calls for “MULTI MOVEMENT PENDANT = MEDIA BRIDGE” 2 Units.</p> <p>As per our email dated 18.02.2019 in which we referred that it is very unusual to have both „Media Bridge“ and the „Ceiling Pendants“ in the same room furthermore technically there is not sufficient space in the ceiling to have both systems installed in the same room and is superfluous!</p>	<p>The bidder is required to comply with the BoQ, drawings, technical specifications and technical compliance sheets, however if during the implementation, any pendant didn't suit the specified room, then it will be transferred to another suitable room.</p>

	<p>The above drawings show no Ceiling pendants in Endoscopy rooms either these have been replaced by amendments but not documented either in drawings nor in BOQ.</p> <p>Alternatively, ceiling pendants may have been planned for another area which again is not clear from drawings nor BOQ.</p>	
2	<p>your drawing AR 105 calls for 2 x Media Bridge and also for 2 x(Surgery/Anesthesia- Pendants) inside Endoscopy 1 &amp; 2</p> <p>It is not usual to have the ceiling Pendants as well as the Media Bridge! There is no room in the ceiling to mount these pendants unless these Pendants are planned for other rooms?</p>	<p>The reason behind this ceiling pendant is for the future extension, because at the time, there is no need for the pendant in the Endoscopy Rooms, but in future, the endoscopy rooms may be changed to operation theaters.</p>