



Empowered lives.
Resilient nations.

April 22nd, 2019

ADDENDUM 04

ITB 099/19 - Rehabilitation of Blood Bank Building in Al Shifaa Hospital Complex-West Mosul-Ninawa Governorate

Following clarifications were sought. Please see the responses

Question via email

Item	Bidders Questions	UNDP Response
1	Concerning ele. section BoQ : Please note that (item 16.31 - 11 kv electrical works) there were difference in cable size between BoQ 1x240mm2 and compliance sheet 1x300mm2 .	Please note that as per BOQ Section 16:13 Letter M (11 kV Power Cables (1x300mm2 CU/XLPE/AWA/PVC) The publish compliance sheet is for this item For Section 16:31 letter A. (240mm ²) there is no compliance sheet. The size is as specified in the BOQ.

This Addendum -04 forms an integral part of the RFQ-099/19 All other Terms and Conditions in this ITB will remain unchanged.

Yours sincerely,


Piero Emanuele Franceschetti
Head of Service Center, UNDP, Iraq

for.