



Empowered lives.
Resilient nations.

April 23th, 2019

ADDENDUM 01

**ITB-111-19 - Rehabilitation of 274 Housing Units in Nabi Jerjes & Ras Al Kur
Neighborhood-Old City Area-West Mosul**

Site Visit

Following clarifications were sought. Please see the responses

Item	Bidders Questions	UNDP Response
1	Can we use Gypsum mortar instead of cement mortar in stone walls building?	No, you can't.
2	Is there any map for the assessed houses?	Yes, there is with coordinates and label for each house. As per attached documents.
3	Does the concrete tests will be required for concrete casting?	YES, according to the Iraqi technical specifications and Iraqi code; for more information you can visit ministry of construction and housing web site: www.moch.gov.iq
4	Is it possible that the contractor can benefit from the old doors, windows etc... From the rehabilitated houses after completing the work?	NO, you can't.

This Addendum -01 forms an integral part of the ITB-111-19 All other Terms and Conditions in this ITB will remain unchanged.

Yours sincerely,


Piero Emanuele Franceschetti
Head of Service Center, UNDP, Iraq