

BBRFQ70470 – Irrigation Components

No.	Question	Response
1.	Pipes made from PVC? Or PE?	Pipes should be PE.
2.	Assuming there is electricity on site, single phase? Or 3 phase?	3 Phase is preferred – Mirabeau is equipped with 3 Phase electricity.
3.	Valve and controller 24Vac or battery operated?	Valve and controller 24Vac.

**NB. Vendors will need to quote for the items that are outlined in the solicitation document.