



April 30, 2019

CLARIFICATION 01

**ITB-104/19 REHABILITATION OF THE UNIVERSITY THEATER HALL-MOSUL UNIVERSITY-EAST MOSUL-NINAWA
GOVERNORATE**

Reference is made to the UNDP published procurement notice for the ITB-104/19 Rehabilitation of the University Theater Hall-Mosul University-East Mosul-Ninawa Governorate on UNDP, UNGM and Development Business websites respectively.


All interested potential bidders are hereby notified about the following clarification:

1. **Question:** Related to the Electrical requirement - Item 39 -Indoor LED Screen Drawing EL -GN-006 section 16772, please confirm the number of Indoor LED Screen (60 Or 6).

Answer: It's 60. Small LED Display will be constructed all together to become 1 large INDOOR LED SCREEN size (6.91M x 2.88M).

2. The Soft version of the forms have been uploaded.
3. The BOQs document with formulas has been uploaded.

This Clarification-01 forms an integral part of the ITB-104/19. All other Terms and Conditions in this ITB will remain unchanged.


Yours sincerely,
Piero Emanuele Franceschetti
Head of Service Center, UNDP, Iraq