



## QUESTIONS AND ANSWERS REPORT

(1)

<b>To:</b>	Bidders
<b>From:</b>	UNDP Syria
<b>Subject:</b>	<b>Providing and Installing Solar Lighting</b>
<b>Reference:</b>	UNDP-SYR-RFQ-033-19
<b>Date:</b>	20 May 2019

The below questions were raised and all questions raised to-date are documented below with respective answers.

### Questions and Answers

Questions and Answers		
1	<b>Q.</b>	Is the data of all MPPT required to showing on the software, or just the MPPT which have data-logging?
	<b>A.</b>	The Data requested is only for the 2 MPPT controllers which have data-logging.
2	<b>Q.</b>	The BOQ shows a total of 32 poles with only 7 concrete bases which gave the intention that the other 25 poles are to be replaced. But, during the site visit, we were told that the number of poles is 25.
	<b>A.</b>	As mentioned in the BOQ the number of required poles is 32, however 25 of them have already a concrete bases and therefore there is a need for only 7 concrete bases to be considered in this project.

All other terms and conditions remain unchanged.