

UNDP's RESPONSES TO SUPPLIERS' QUESTIONS**BB-73756 - RFQ for the Supply and Delivery of Electrical Materials to Dominica****Bid Submission Deadline: 6 June 2019, 5p.m. AST**

No.	Question	UNDP Response
1	<p>Documents to be submitted by Bidder - <input checked="" type="checkbox"/>Duly Accomplished Form as provided in Annex 2, in accordance with the list of requirements in Annex 1; <input checked="" type="checkbox"/>Company Profile which should not exceed fifteen (15) pages, which can include printed brochures and product catalogues relevant to the goods and/or services being procured <input checked="" type="checkbox"/>Latest Business Registration Certificate; <input checked="" type="checkbox"/>Latest Internal Revenue Certificate / Tax Clearance;</p> <p><i>Question: We are a company based in the US, could we participate in this tender?</i></p>	<p>Yes, US based companies are permitted to participate in this tender. Please submit all documents as required by the RFQ.</p>
2	<p>Item 28 - Structural Steel #2 cable bonding- Quantity :16 - <i>What size is required?</i></p>	<p>Item is a bonding clamp suitable to fasten #2 braided copper to 1/4" structural steel</p>
3	<p>Item 29 - Ground rod #2 bonding- quantity 12. <i>What size is required?</i></p>	<p>Item is a bonding clamp suitable to fasten #2 braided copper to 5/8 in copper ground rod</p>
4	<p>Item 30- Water pipe #2 bonding- quantity 4 <i>What size is required?</i></p>	<p>Item is a bonding clamp suitable to fasten #2 braided copper to 2" galv. Steel conduit</p>
5	<p>Item 35- Carrier wire steel – Quantity 300 <i>What size is required?</i></p>	<p>1/4" galvanized steel</p>
6	<p>Item 36- 8 pair telephone cable- Quantity 300 <i>How many feet?</i></p>	<p>The Unit of Measure to be considered for this item is feet. Therefore 300 feet is required in total. Suitable for aerial use.</p>
7.	<p>Item 37- Cat 5 Ethernet cable – Quantity 300 <i>How many feet?</i></p>	<p>The Unit of Measure to be considered for this item is feet. Suitable for aerial use.</p>
8.	<p>Item 37- Cat 5 Ethernet cable – Quantity 300 <i>How many feet?</i></p>	<p>The Unit of Measure to be considered for this item is feet. Suitable for aerial use.</p>

9.	43# 12 thhn copper wire green – Quantity 6000 44# 12 thhn copper wire blue – Quantity 6000 45# 12 thhn copper wire brown – Quantity 6000 46#10 thhn copper wire green – Quantity 3000 47#10 thhn copper wire blue – Quantity 3000 48#10 thhn copper wire brown – Quantity 3000 Item 43- 48 How many feet required per item?	The Unit of Measure to be considered for these items is feet.
10.	Item 49 - 3/4 " plastic pipe conduit 9500 503/4 " plastic pipe elbows What length is required? Item 50- 3/4 " plastic pipe elbows – Quantity 200 What angle required? 45 degrees, 90 degrees?	Item 49 is 3/4 inch plastic pipe conduit, quantity 9500 feet, 90 degrees Item 50 is 3/4 inch plastic conduit pipe elbows, 90 degrees
11.	Item 52 - 3/0 THWN wire blue – Quantity 150 What length is required?	The Unit of Measure to be considered for this item is feet.
12.	Item 54- #2 thhn copper wire green – Quantity 50 Item 55- #2 thhn copper wire blue – Quantity 50 Item 56- #2 thhn copper wire brown – Quantity 50 What length is required?	The Unit of Measure to be considered for this item is feet.
13.	Item 57- Pull and junction boxes 1 wide with finish covers – Quantity 10 Please indicate Height, Length and Width required.	4” x 2” 1 7/8 “deep one gang
14.	Item 58- 2 wide (square)- Quantity 100 More information required on the product please.	4” x 4” 1 1/2 “deep two gang
15.	Item 59 - 3 wide – Quantity 60 More information required on the product please.	8.7 “by 4.5” x 1 5/8” deep three gang

Additional Notes:

- Electric service in Dominica is 230 volt, 50 cycle and all fixtures and appliances should be compatible.
- References to a brand names are for illustrative purposes only. Bidders quoting an alternate brand must provide the product data sheet to show that the product is comparable.