

UNDP's RESPONSES TO SUPPLIERS' QUESTIONS**ROUND #2****BB-73756 - RFQ for the Supply and Delivery of Electrical Materials to Dominica****Bid Submission Deadline: 6 June 2019, 5p.m. AST**

No.	Question	UNDP Response
1	<p>Item #34 - Overhead service drop cable 2 wire XIPE NFC 33-209 300 FT For the overhead, please clarify.</p> <ul style="list-style-type: none"> - Conductor size - Number of conductors - Rating 	<ul style="list-style-type: none"> - Conductor size 3/0 copper - Number of conductors 2 - Rating 200 A -
2	<p>Item #36 – 8 paid phone cable 300 ft. Please clarify:</p> <ul style="list-style-type: none"> - Direct burial etc? - Plenum or riser? - Shielding? - Wire gauge? 	<ul style="list-style-type: none"> - Direct burial etc? suitable for aerial use - Plenum or riser? suitable for aerial use - Shielding? Yes - Wire gauge? 25 -
3	<p>Item #37 – CAT 5 Ethernet cable Please clarify:</p> <ul style="list-style-type: none"> - Plenum or riser - Direct burial - Color - Shielding 	<ul style="list-style-type: none"> - Plenum or riser suitable for aerial use - Direct burial suitable for aerial use - Color Any - Shielding Yes -

Notes:

- Electric service in Dominica is 230 volt, 50 cycle and all fixtures and appliances should be compatible.
- References to a brand names are for illustrative purposes only. Bidders quoting an alternate brand must provide the product data sheet to show that the product is comparable.