



QUESTIONS AND ANSWERS REPORT

To: Bidders

From: UNDP Syria

Subject: Rehabilitation and Maintenance of the Sewage Network in Harasta , Douma and Kafar Batana

Reference: UNDP-SYR-ITB-072-19

Date : 17-07-2019

UNDP Syria Procurement Unit and after the site visit of UNDP premises they received some questions regarding the subject Tendering Procedure. All questions received to-date are documented below with respective answers.

Question 1:

1. in Duma's scope of work point 5:

قساقل بيتون مسلح نهاية مستقيمة صنف أول عيار 350 كغ / م 3 اسمنت مقاوم للكبريتات قطر 50 سم طول 1 مترسماكة 5سم.

Q: ما المقصود بقطر 50 (القطر الداخلي ام الخارجي) ؟

Answer 1-

القطر الخارجي للقساقل هو 50 سم أما القطر الداخلي 40 سم

Question 2:

in Duma's scope of work point 6:

قساقل بيتون مسلح نهاية مستقيمة صنف أول عيار 350 كغ / م 3 اسمنت مقاوم للكبريتات قطر 80 سم طول 1 مترسماكة 5سم

Q: ما المقصود بقطر 80(القطر الداخلي ام الخارجي) ؟

Answer 2

القطر الخارجي للقساقل هو 80سم أما القطر الداخلي 60سم

Question 2:

in Kafar Batna's scope of work point 7:

قساقل بيتون مسلح نهاية مستقيمة صنف أول عيار 350 كغ / م 3 اسمنت مقاوم للكبريتات قطر 50 سم طول 1 مترسماكة 5سم

Q: ما المقصود بقطر 50 (القطر الداخلي ام الخارجي)

Answer 2

القطر الخارجي للقساطل هو 50 سم أما القطر الداخلي 40 سم

All other terms and conditions remain unchanged