

**UNDP CYP ITB 077 2019 - Conservation works at the Sourp Magar Monastery**

**Clarifications no:1 dated 8 August 2019**

	Questions	Answers
1	<p>In Bill 4, page 4 item 05 there is a reference to Work Description CS11. In Section 5C9 Proposal Drawings, drawings A-Pr 12, we see a description for CS11 which reads "Repair of Existing Concrete slab". However, we cannot find in the drawings the location and sizes of the slab. This information is necessary as the item in BoQ is to be priced as a lump sum item. Therefore, could you please advise where the aforementioned works are to be carried out?</p>	<p>SC11 refers to the concrete slab located on the north part of Block C. Drawing A-PR03 figures 1, 2, 3. Dimensions are 6.7mx3.2m.</p>
2	<p>Bill No 6, Block E, page 4, item 03 Existing floor of Chapel of Monastery 44m2</p> <p>Consolidation of existing historic floors including: carefully clean existing floor to reveal historic floor tiles: identify protect and store for reuse any loose existing tiles previously removed: carefully examine all tiles individually in position remove loose tiles: clean and fix back to original position: fill joints as necessary: replacement of missing floor tiles with new as existing: all according to Technical Specifications, Particular Technical Specifications Section 2.2.20 [S22] , details on drawing A-Pr19 and the instructions of the Engineer (Work Description ES8)</p> <p>It might not be possible to find similar tiles. Are there any original tiles stored on the site that can be provided by the Employer for Contractor to install?</p>	<p>Once the site debris is cleaned and tiles will be exposed some tiles may be found. If not, missing tiles will be replaced with "<b><u>new as existing</u></b>".</p>
3	<p>Section 5C4 – Proposal Drawing (Steel Enclosures)</p> <p>In this set of drawings, the same frames are sometimes shown as 50x50 galvanised box and sometimes as 40x04 painted box. Which one is correct?</p>	<p>Drawing A-Pr 22 shows galvanized boxes as 40x40mm. Please specify in which drawing 50x50mm or 40x04mm are written.</p>

4	We would like to visit the site. Will a site visit be organised by UNDP? If not, is the site accessible? Is an advance notice necessary before we visit the site?	The site is accessible, no advance notice is required. A site visit will not be organized by UNDP.
---	---	--